CUYAMA COMMUNITY SERVICES DISTRICT Water Quality Data Calendar Year 2023

WATER TREATMENT PLANT												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Average Usage Gallons Per Day	72,000											
Arsenic ppb	4.7											
lron ppb	ND											
Total Dissolved Solids mg/L	1000											
Total Recoverable Calcium mg/L	110											
Total Recoverable Magnesium mg/L	19											
Hardness as CaCO3 mg/L	350											

WATER WELL #1												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Arsenic												
ppb	55											
Total Coliform												
MPN/100 ml	<1											
E. Coli												
MPN/100 ml	<1											
Total Dissolved												
Solids mg/L												

DISTRIBUTION												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Residual Chlorine												
ppm	0.91											
Total Coliform												
MPN/100 ml	<1											
E. Coli												
MPN/100 ml	<1											