

**CUYAMA COMMUNITY SERVICES DISTRICT**  
**Water Quality Data**  
**Calendar Year 2025**

<b>WATER TREATMENT PLANT</b>												
<b>CONSTITUENT</b>	<b>JAN</b>	<b>FEB</b>	<b>MAR</b>	<b>APR</b>	<b>MAY</b>	<b>JUNE</b>	<b>JULY</b>	<b>AUG</b>	<b>SEPT</b>	<b>OCT</b>	<b>NOV</b>	<b>DEC</b>
Average Usage Gallons Per Day	97,000	101,000	119,000	154,000	155,000	196,000	237,000					
Arsenic ppb	4.7	3.8	3.3	5.3	5.1	4.6	5.2					
Iron ppb	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

<b>WATER WELL #1</b>												
<b>CONSTITUENT</b>	<b>JAN</b>	<b>FEB</b>	<b>MAR</b>	<b>APR</b>	<b>MAY</b>	<b>JUNE</b>	<b>JULY</b>	<b>AUG</b>	<b>SEPT</b>	<b>OCT</b>	<b>NOV</b>	<b>DEC</b>
Production Acre Feet	9.130	8.608	11.186	13.985	14.764	18.189	22.093					
Arsenic ppb	49	50	45	44	50	46	45					
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
Total Dissolved Solids mg/L				930								

<b>DISTRIBUTION</b>												
<b>CONSTITUENT</b>	<b>JAN</b>	<b>FEB</b>	<b>MAR</b>	<b>APR</b>	<b>MAY</b>	<b>JUNE</b>	<b>JULY</b>	<b>AUG</b>	<b>SEPT</b>	<b>OCT</b>	<b>NOV</b>	<b>DEC</b>
Residual Chlorine ppm	1.01	0.97	0.96	1.10	0.95	0.99	0.97					
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					