

CUYAMA COMMUNITY SERVICES DISTRICT
Water Quality Data
Calendar Year 2026

WATER TREATMENT PLANT												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Average Usage Gallons Per Day	64,000	69,000	108,000	134,000	175,000	208,000	194,000					
Arsenic ppb	4.1	4.3	4.2	4.4	5.8	4.0	4.5					
Iron ppb	N/A	N/A	N/A	N/A	N/A	N/A	N/A					
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

WATER WELL #1												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Production Acre Feet	7.374	7.371	10.354	12.322	16.296	18.303	17.545					
Arsenic ppb	47	51	47	42	43	42	48					
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
Total Dissolved Solids mg/L												

DISTRIBUTION												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Residual Chlorine ppm	0.99	0.84	0.80	0.74	0.75	0.70	0.70					
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1					