CUYAMA COMMUNITY SERVICES DISTRICT
Water Quality Data
Calendar Year 2025

WATER TREATMENT PLANT												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Average Usage Gallons Per Day	97,000	101,000	119,000	154,000	155,000	196,000	237,000	289,000	208,000	143,000	115,000	78,000
Arsenic ppb	4.7	3.8	3.3	5.3	5.1	4.6	5.2	6.0	5.8	2.9	5.5	4.2
Iron ppb	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

WATER WELL #1												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Production Acre Feet	9.130	8.608	11.186	13.985	14.764	18.189	22.093	26.696	18.705	13.494	10.551	8.139
Arsenic ppb	49	50	45	44	50	46	45	52	46	44	66	46
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
Total Dissolved Solids mg/L				930								

DISTRIBUTION												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Residual Chlorine ppm	1.01	0.97	0.96	1.10	0.95	0.99	0.97	0.99	0.89	0.81	0.78	0.79
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1