CUYAMA COMMUNITY SERVICES DISTRICT Water Quality Data Calendar Year 2021

WATER TREATMENT PLANT												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Average Usage	22.000	45.000	45.000	75 000	405.000	405 000	000 000	000 000	000 000	405 000	100.000	
Gallons Per Day	33,000	15,000	45,000	75,000	125,000	165,000	220,000	220,000	200,000	125,000	100,000	
Arsenic												
ppb	3.0	3.5	6.7	8.2	6.7	5.5	6.8	4.5	6.0	10	4.2	
Iron												
ppb	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
Total Dissolved												
Solids mg/L						1100	1000	1000	1000			
Total Recoverable												
Calcium mg/L							100	99	100			
Total Recoverable												
Magnesium mg/L							18	18	19			
Hardness as CaCO3												
mg/L							330	320	340			

WATER WELL #1												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Arsenic ppb	49	48	51	52	52	47	49	47	46	52	47	
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	
E. Coli MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	
Total Dissolved Solids mg/L						1000						

DISTRIBUTION												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Residual Chlorine												
ppm	1.10	1.29	0.91	0.91	1.02	0.99	0.71	0.67	0.71	0.91	1.21	
Total Coliform												
MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	
E. Coli												
MPN/100 ml	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	<1	