

CUYAMA COMMUNITY SERVICES DISTRICT
Water Quality Data
Calendar Year 2024

| WATER TREATMENT PLANT | | | | | | | | | | | | |
|-------------------------------------|--------|--------|--------|--------|---------|---------|------|-----|------|-----|-----|-----|
| CONSTITUENT | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG | SEPT | OCT | NOV | DEC |
| Average Usage Gallons Per Day | 71,000 | 63,000 | 78,000 | 92,000 | 152,000 | 185,000 | | | | | | |
| Arsenic ppb | 4.94 | 5.48 | 6.04 | 5.26 | 5.5 | 5.8 | | | | | | |
| Iron ppb | ND | ND | ND | <100 | <100 | <100 | | | | | | |
| Total Dissolved Solids mg/L | | | | | | | | | | | | |
| Total Recoverable Calcium mg/L | | | | | | | | | | | | |
| Total Recoverable Magnesium mg/L | | | | | | | | | | | | |
| Hardness as CaCO3 mg/L | | | | | | | | | | | | |

| WATER WELL #1 | | | | | | | | | | | | |
|--------------------------------|-------|-------|-------|-------|--------|--------|------|-----|------|-----|-----|-----|
| CONSTITUENT | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG | SEPT | OCT | NOV | DEC |
| Production Acre Feet | 6.819 | 5.493 | 7.215 | 8.421 | 14.279 | 16.916 | | | | | | |
| Arsenic ppb | 47.6 | 52.7 | 43.3 | 44.2 | 46 | 40 | | | | | | |
| Total Coliform MPN/100 ml | <1 | <1 | <1 | <1 | <1 | <1 | | | | | | |
| E. Coli MPN/100 ml | <1 | <1 | <1 | <1 | <1 | <1 | | | | | | |
| Total Dissolved Solids mg/L | | | | | | | | | | | | |

| DISTRIBUTION | | | | | | | | | | | | |
|------------------------------|------|------|------|------|------|------|------|-----|------|-----|-----|-----|
| CONSTITUENT | JAN | FEB | MAR | APR | MAY | JUNE | JULY | AUG | SEPT | OCT | NOV | DEC |
| Residual Chlorine ppm | 1.01 | 0.97 | 0.93 | 1.10 | 0.48 | 0.55 | | | | | | |
| Total Coliform MPN/100 ml | <1 | <1 | <1 | <1 | <1 | <1 | | | | | | |
| E. Coli MPN/100 ml | <1 | <1 | <1 | <1 | <1 | <1 | | | | | | |