CUYAMA COMMUNITY SERVICES DISTRICT Water Quality Data Calendar Year 2025

WATER TREATMENT PLANT												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Average Usage Gallons Per Day	97,000											
Arsenic ppb	4.70											
lron ppb	N/A											
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

WATER WELL #1												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Production Acre Feet	9.130											
Arsenic ppb	49											
Total Coliform MPN/100 ml	<1											
E. Coli MPN/100 ml	<1											
Total Dissolved Solids mg/L												

DISTRIBUTION												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	ОСТ	NOV	DEC
Residual Chlorine												
ppm	1.01											
Total Coliform												
MPN/100 ml	<1											
E. Coli												
MPN/100 ml	<1											