

**CUYAMA COMMUNITY SERVICES DISTRICT**  
**Water Quality Data**  
**Calendar Year 2024**

WATER TREATMENT PLANT												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Average Usage Gallons Per Day	71,000	63,000	78,000	92,000	152,000							
Arsenic ppb	4.94	5.48	6.04	5.26	5.5							
Iron ppb	ND	ND	ND	<100	<100							
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

WATER WELL #1												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Production Acre Feet	6.819	5.493	7.215	8.421	14.279							
Arsenic ppb	47.6	52.7	43.3	44.2	46							
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1							
E. Coli MPN/100 ml	<1	<1	<1	<1	<1							
Total Dissolved Solids mg/L												

DISTRIBUTION												
CONSTITUENT	JAN	FEB	MAR	APR	MAY	JUNE	JULY	AUG	SEPT	OCT	NOV	DEC
Residual Chlorine ppm	1.01	0.97	0.93	1.10	0.48							
Total Coliform MPN/100 ml	<1	<1	<1	<1	<1							
E. Coli MPN/100 ml	<1	<1	<1	<1	<1							