CUYAMA COMMUNITY SERVICES DISTRICT
Water Quality Data
Calendar Year 2026

WATER TREATMENT PLANT												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Average Usage Gallons Per Day	64,000	69,000	108,000									
Arsenic ppb	4.1	4.3	4.2									
Iron ppb	N/A	N/A	N/A									
Total Dissolved Solids mg/L												
Total Recoverable Calcium mg/L												
Total Recoverable Magnesium mg/L												
Hardness as CaCO3 mg/L												

WATER WELL #1												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Production Acre Feet	7.374	7.371	10.354									
Arsenic ppb	47	51	47									
Total Coliform MPN/100 ml	<1	<1	<1									
E. Coli MPN/100 ml	<1	<1	<1									
Total Dissolved Solids mg/L												

DISTRIBUTION												
CONSTITUENT	**JAN**	**FEB**	**MAR**	**APR**	**MAY**	**JUNE**	**JULY**	**AUG**	**SEPT**	**OCT**	**NOV**	**DEC**
Residual Chlorine ppm	0.99	0.84	0.80									
Total Coliform MPN/100 ml	<1	<1	<1									
E. Coli MPN/100 ml	<1	<1	<1									